Declaration of Performance (DoP): **GEZE TS 2000 NV BC**

ID for Declaration of Performance	**GEZE TS 2000 NV BC_0672-CPD-0106**
1. Type of product	Door closer system
2. Identity numbers	102431, 102433, 102432, 102434, 102421, 102422, 102423, 102426, 102425, 124944, 124945, 124946, 124947
3. Intended use	Door closer with controlled closing procedure for use on fire and/or smoke protection doors or on emergency exits
4. Manufacturer	GEZE GmbH, Reinhold-Vöster-Str. 21-29, D-71229 Leonberg
5. Authorised signatory	---
6. System for evaluating performance reliability	1
7. Harmonised standard	EN 1154:1996 + A1:2002
8.1. Notified office	MPA Stuttgart, Pfaffenwaldring 32, D-70569 Stuttgart, Notified Body ID = 0672
8.2. ID certificate	0672-CPD-0106
9. Declared performance	**Essential characteristics determined**
EN 1154 - Self-closing	"Self-closing" requirements fulfilled - EN 1154:1996 + A1:2002 sections 5.2.1, 5.2.3 - 5.2.16, 5.2.18
EN 1154 - Permanent function of the self-closing feature	"Permanent function" requirements fulfilled - EN 1154:1996 + A1:2002 sections 5.2.2, 5.2.17.1, 5.2.17.2
Hazardous substances	No hazardous substances in the sense of the EC guidelines and REACH directive
EN 1154 Classification	
Application class	4 (Class 3 = close from at least 105°, 4 = close from 180°)
Permanent function of self-closing	8 (Class 8 = 500,000 cycles)
Door closer size	2-4 (door closer sizes = 1-7)
Suitability for use on fire/smoke protection doors	1 (Class 0 = not suitable, 1 = suitable)
Safety	1 (Class 1 = Safe use)
Corrosion resistance	4 (acc. to EN 1670: Class 0 = none defined, Class 1 = low, Class 2 medium, Class 3 = high, Class 4 = very high)
10. Product performance	The performance of the product specified under No. 1 corresponds to the declared performance according to No. 9. The manufacturer under No. 4 is solely responsible for preparing the declaration of performance according to No. 9.
Place, date	Leonberg, 14.06.2013
Hermann Alber, Managing Director	